

C E R T I F I C A T E
of Conformity



Registration No.: AK 50535298 0001

Report No.: CN20VKHD 003

Holder: GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Product: PV-Inverter
(Grid-connected PV inverter)

Identification: Type Designation: GEP30-L-10 GEP35-L-10
GEP50-10 GEP60-10
GW30KLS-MT GW35KLS-MT
GW50KS-MT GW60KS-MT
Serial Number : Engineering samples
Remark : Refer to test report CN20VKHD 003
for details.

Tested acc. to: IEC 61727:2004
IEC 62116:2014

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 09.03.2022

Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

GoodWe Technologies Co., Ltd.
Mr. Jiang Tao

Date : 09.03.2022
Our ref. : Kese 01
Your ref.: Jing Xie

No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-connected PV inverter
Model Designation : See Certificate
Certificate No. : AK 50535298 0001
Report No. : CN20VKHD 003

Dear Mr. Jiang Tao,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询